



# UNITED STATES PATENT AND TRADEMARK OFFICE

*clb*

UNITED STATES DEPARTMENT OF COMMERCE  
United States Patent and Trademark Office  
Address: COMMISSIONER FOR PATENTS  
P.O. Box 1450  
Alexandria, Virginia 22313-1450  
www.uspto.gov

APPLICATION NO.	FILING DATE	FIRST NAMED INVENTOR	ATTORNEY DOCKET NO.	CONFIRMATION NO.
09/196,680	11/20/1998	STEPHEN J. MEYER	052250-5008	9428
9629	7590	04/06/2004	EXAMINER	
MORGAN LEWIS & BOCKIUS LLP 1111 PENNSYLVANIA AVENUE NW WASHINGTON, DC 20004			KIM, CHRISTOPHER S	
			ART UNIT	PAPER NUMBER
			3752	

DATE MAILED: 04/06/2004

*40*

Please find below and/or attached an Office communication concerning this application or proceeding.

# Office Action Summary

Application No.

09/196,680

Applicant(s)

MEYER ET AL.

Examiner

Christopher S. Kim

Art Unit

3752

-- The MAILING DATE of this communication appears on the cover sheet with the correspondence address --

## Period for Reply

A SHORTENED STATUTORY PERIOD FOR REPLY IS SET TO EXPIRE 3 MONTH(S) FROM THE MAILING DATE OF THIS COMMUNICATION.

- Extensions of time may be available under the provisions of 37 CFR 1.136(a). In no event, however, may a reply be timely filed after SIX (6) MONTHS from the mailing date of this communication.
- If the period for reply specified above is less than thirty (30) days, a reply within the statutory minimum of thirty (30) days will be considered timely.
- If NO period for reply is specified above, the maximum statutory period will apply and will expire SIX (6) MONTHS from the mailing date of this communication.
- Failure to reply within the set or extended period for reply will, by statute, cause the application to become ABANDONED (35 U.S.C. § 133). Any reply received by the Office later than three months after the mailing date of this communication, even if timely filed, may reduce any earned patent term adjustment. See 37 CFR 1.704(b).

## Status

- 1) ☒ Responsive to communication(s) filed on 03 February 2004.
- 2a) ☐ This action is **FINAL**. 2b) ☒ This action is non-final.
- 3) ☐ Since this application is in condition for allowance except for formal matters, prosecution as to the merits is closed in accordance with the practice under *Ex parte Quayle*, 1935 C.D. 11, 453 O.G. 213.

## Disposition of Claims

- 4) ☒ Claim(s) 1-11, 14, 15 and 20-62 is/are pending in the application.
- 4a) Of the above claim(s) 55-61 is/are withdrawn from consideration.
- 5) ☐ Claim(s) \_\_\_\_\_ is/are allowed.
- 6) ☒ Claim(s) 1-11, 14, 15, 20-54 and 62 is/are rejected.
- 7) ☐ Claim(s) \_\_\_\_\_ is/are objected to.
- 8) ☐ Claim(s) \_\_\_\_\_ are subject to restriction and/or election requirement.

## Application Papers

- 9) ☐ The specification is objected to by the Examiner.
- 10) ☐ The drawing(s) filed on \_\_\_\_\_ is/are: a) ☐ accepted or b) ☐ objected to by the Examiner.  
Applicant may not request that any objection to the drawing(s) be held in abeyance. See 37 CFR 1.85(a).  
Replacement drawing sheet(s) including the correction is required if the drawing(s) is objected to. See 37 CFR 1.121(d).
- 11) ☐ The oath or declaration is objected to by the Examiner. Note the attached Office Action or form PTO-152.

## Priority under 35 U.S.C. § 119

- 12) ☐ Acknowledgment is made of a claim for foreign priority under 35 U.S.C. § 119(a)-(d) or (f).
- a) ☐ All b) ☐ Some \* c) ☐ None of:
- ☐ Certified copies of the priority documents have been received.
  - ☐ Certified copies of the priority documents have been received in Application No. \_\_\_\_\_.
  - ☐ Copies of the certified copies of the priority documents have been received in this National Stage application from the International Bureau (PCT Rule 17.2(a)).
- \* See the attached detailed Office action for a list of the certified copies not received.

## Attachment(s)

- ☐ Notice of References Cited (PTO-892)
- ☐ Notice of Draftsperson's Patent Drawing Review (PTO-948)
- ☐ Information Disclosure Statement(s) (PTO-1449 or PTO/SB/08)  
Paper No(s)/Mail Date \_\_\_\_\_
- ☐ Interview Summary (PTO-413)  
Paper No(s)/Mail Date. \_\_\_\_\_
- ☐ Notice of Informal Patent Application (PTO-152)
- ☐ Other: \_\_\_\_\_

## **DETAILED ACTION**

### ***Continued Examination Under 37 CFR 1.114***

1. A request for continued examination under 37 CFR 1.114, including the fee set forth in 37 CFR 1.17(e), was filed in this application after final rejection. Since this application is eligible for continued examination under 37 CFR 1.114, and the fee set forth in 37 CFR 1.17(e) has been timely paid, the finality of the previous Office action has been withdrawn pursuant to 37 CFR 1.114. Applicant's submission filed on February 3, 2004 has been entered.
2. The text of those sections of Title 35, U.S. Code not included in this action can be found in a prior Office action.

### ***Claim Rejections - 35 USC § 112***

3. Claims 1-11, 14, 15, 20-54 and 62 are rejected under 35 U.S.C. 112, second paragraph, as being indefinite for failing to particularly point out and distinctly claim the subject matter which applicant regards as the invention.

Independent claims 1, 20, 24, 25, 42, 45, 46, 47, 48 and 50 were previously directed to a sprinkler but have been amended to further recite "...and when the sidewall fire sprinkler is paired with an identical sidewall fire sprinkler mounted approximately sixteen feet apart on a generally planar wall surface with a collection area of approximately sixteen feet between the sprinklers and sixteen feet away from one of the sprinklers, the collection area located at either one of a distance of about thirty-six

inches and a distance of approximately six feet and 7.5 inches below each of the sidewall fire sprinklers so that water is delivered to the collection area at an average density of about 0.15 gallons per minute per square feet." The added recitation appears to be a conditional requirement. It is uncertain whether applicant is claiming a sprinkler (as recited by the preamble) or a combination of two identical sprinklers (recited in the body of the claim). This Office action treats the added recitation as a conditional requirement, i.e., the claim does not positively require two sprinklers. If two sprinklers were to be mounted as recited in the claims, the claimed collection result would inherently occur because the result is a function of the characteristics/properties of sprinkler. The installation is per NFPA Standard 13 specification discloses, on page 11, lines 5-10) which is well known.

***Claim Rejections - 35 USC § 103***

4. Claims 1-11, 14, 15, 20-54 and 62 are rejected under 35 U.S.C. 103(a) as being unpatentable over Fischer in view of Tramm.

Fischer discloses a sprinkler comprising: a generally tubular body 30 having a central passageway 31, a closure 40, a trigger 44, a deflector 38; a face portion 76; a canopy portion 62; two frame arms 34; two support arms (no reference numbers); a single flow opening 79. Fischer teaches the use of a deflector 38 shaped and positioned to transform a horizontal flow of water into a spray pattern of droplets dispersed over a generally horizontal, rectangularly-shaped coverage area (see figures 1 and 6). The coverage area may be up to 16 ft x 24 ft (see column 3 lines 55-58).

Tramm discloses, in column 5, lines 12-14, a horizontal-type fire protection sprinkler having a K-factor of at least 3.5, or at least 5.0, or at least 7.0, or at least 10.5, or at least 13.0. It would have been obvious to a person of ordinary skill in the art at the time the invention was made to have provided the sprinkler of Fischer with the range of K-factors (greater than 9) as taught by Tramm to provide a specific flow rate depending on pressure.

The device of Fischer in view of Tramm discloses the claimed limitation with the exception of the water flow rate and coverage area being at a height of only three feet below the canopy portion of the deflector. Fischer in view of Tramm discloses the structural limitations, K-factors including the relationship between flow rates and pressures, and the coverage area. It would have been obvious to a person of ordinary skill in the art at the time the invention was made to have positioned the sprinkler of Fischer in view of Tramm three feet above the coverage area to extinguish fires in three feet high compartments.

Fischer discloses the limitations of the claimed invention with the exception of the liquid filled glass bulb. Tramm discloses, pictorially, in figure 2, a liquid filled glass bulb 20. It would have been obvious to a person of ordinary skill in the art at the time the invention was made to have replaced the trigger of Fischer with the trigger (liquid filled glass bulb) of Tramm to eliminate the need for solder.

Fischer discloses, in column 3, lines 55-58, a coverage area of 16 ft x 24 ft (using a deflector comprising a generally planar face portion and a canopy portion, see figure 2). It would have been obvious to a person of ordinary skill in the art at the time the

invention was made that the coverage area is dependent on the fluid pressure, and therefore, any coverage area less than 16 ft x 24 ft can be attained by reducing the pressure (or increasing the K-factor which results in a lower pressure as defined by the formula in column 5, lines 30-38 of Tramm). It would have been obvious to a person of ordinary skill in the art at the time the invention was made to have adjusted the coverage area depending on the size of the room, since it has been held that where the general conditions of a claim are disclosed in the prior art, discovering the optimum or workable ranges involves only routine skill in the art. *In re Aller*, 105 USPQ 233.

Since Fischer in view of Tramm discloses the structural and functional recitation of the claims, the device of Fischer in view of Tramm would inherently produced the collection are result "when" mounted per NFPA Standard 13.

### ***Response to Arguments***

5. Applicant's arguments filed February 03, 2004 have been fully considered but they are not persuasive.

Applicant argues that Fishcer in view of Tramm does not disclose "...and when the sidewall fire sprinkler is paired with an identical sidewall fire sprinkler mounted approximately sixteen feet apart on a generally planar wall surface with a collection area of approximately sixteen feet between the sprinklers and sixteen feet away from one of the sprinklers, the collection area located at either one of a distance of about thirty-six inches and a distance of approximately six feet and 7.5 inches below each of the sidewall fire sprinklers so that water is delivered to the collection area at an average


density of about 0.15 gallons per minute per square feet." Since Fischer in view of Tramm discloses the structural and functional recitation of the claims, the device of Fischer in view of Tramm would inherently produced the collection are result "when" mounted per NFPA Standard 13.

### ***Conclusion***

Any inquiry concerning this communication or earlier communications from the examiner should be directed to Christopher S. Kim whose telephone number is (703) 308-8336. The examiner can normally be reached on Monday - Thursday, 6:30 AM - 5:00 PM.

If attempts to reach the examiner by telephone are unsuccessful, the examiner's supervisor, Michael Y. Mar can be reached on (703) 308-2087. The fax phone number for the organization where this application or proceeding is assigned is 703-872-9306.

Information regarding the status of an application may be obtained from the Patent Application Information Retrieval (PAIR) system. Status information for published applications may be obtained from either Private PAIR or Public PAIR. Status information for unpublished applications is available through Private PAIR only. For more information about the PAIR system, see <http://pair-direct.uspto.gov>. Should you have questions on access to the Private PAIR system, contact the Electronic Business Center (EBC) at 866-217-9197 (toll-free).

  
Christopher S. Kim  
Primary Examiner  
Art Unit 3752

CK